

TAB. "TGN" I LINE CAT. LA400M181B, CLASE 2110 TAMAÑO 3  
CON INTERRUPTOR PRINCIPAL 3 X 400 AMP. POWERPACT

1,620                      1,650                      1,600

SERVICIO A CONECTAR	LOCALIZACION		SUBTOTAL DE WATTS	WATTS A FASE			LONGITUD CONDUCTOR MTS.	CAIDA TENSION %e	CORRIENTE AMPS.	COND. MIN CAL.	PROTECCION	
				A	B	C					POLOS	TERM AMPS
TABLERO "AN"	PASILLOS		4870	1620	1650	1600	58	0.98	14.20	6	3	30
TABLERO "BN"	PASILLOS		11,620	3900	3870	3850	34	0.86	33.88	4	3	50
TABLERO "CN"	PASILLOS		5400	2775		2625	25	1.11	23.62	8	2	30
TABLERO "DN"	PLANTA DE EMERGENCIA		1866		933	933	7	0.11	8.16	8	2	20
VE-02	AZOTEA		375		187	188	50	0.25	1.64	8	2	15
VE-03	AZOTEA		188		94	94	50	0.08	0.82	8	2	15
U.P.1.	AZOTEA		17535	5845	5845	5845	50	0.75	51.13	1/0	3	80
U.P.2	AZOTEA		11215	3738	3738	3739	50	0.77	32.7	2	3	60
UMA-02	AZOTEA		563	187	188	188	48	0.15	1.64	8	3	15
UCA-02	AZOTEA		11215	3738	3738	3739	50	0.77	32.7	2	3	60
AUTO CLAVE LUMINARIA EXTERIOR	AREA DE CEYE. OBRA EXTERIOR		11000 1680	3666	3667	3667	62 85	1.48 0.74	32.07 7.35	4 6	3 2	50 20
TAB. DE EMERG.	PLANTA DE SERVICIOS		65473	21824	21824	21825	10	0.56	190.91	2-1/0	3	250
TOTALES			143000	47293	46574	49133			430.82			